

Vegetation Management

Resilience Investment Guide

SEPTEMBER 2024



BERKELEY LAB

Bringing Science Solutions to the World

Disclaimer

This work was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their - employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof, its contractors or subcontractors.

Acknowledgments

This report was prepared by Lawrence Berkeley National Laboratory for the U.S. Department of Energy, Grid Deployment Office.

Resilience Investment Strategy Overview

This resilience investment guide is one of six guides that describes the costs and benefits of a range of projects that are eligible under the Grid Resilience State and Tribal Formula Grant program and the Grid Resilience Utility Industry Grant program as described in Section 40101 of the Bipartisan Infrastructure Law (BIL). These two U.S. Department of Energy (DOE) grant programs are designed to enhance electric grid resilience against extreme weather, wildfire, and other natural disasters and are intended for states; federally recognized Indian tribes, including Alaska Native Village and Regional Corporations; U.S. territories; electric grid operators; electricity storage operators; electricity generators; transmission owners or operators; distribution providers; and fuel suppliers. This specific guide provides an overview of vegetation management practices.

Vegetation-related impacts to the power system are the most common cause of power outages in the U.S., accounting for more than twenty percent of incidents [1,2]. Effective vegetation management practices reduce the occurrence of these events through the implementation of:

- **tree pruning**, usually on a regular cycle – cutting back tree growth to maintain clearances from utility transmission and distribution overhead lines.
- **tree removal** – taking out damaged, unhealthy, or dead trees in proximity to utility lines.
- **vegetation control** – removal of flammable brush and suppression of hazardous brush growth.
- **integrated vegetation management** – combining the previous methods with other measures that promote “desirable, stable, low-growing plant communities that will resist invasion by tall-growing tree species through the use of appropriate, environmentally-sound, and cost-effective control methods” [3].
- **widening rights-of-way** – this would require the approval of local and state governments, but widening the area around utility poles and wires, where the utility is allowed to trim trees could significantly reduce vegetation related outages. The state of California, for example, has several laws for distribution line vegetation management, requiring greater distance (4 ft vs 1.5 ft) between wires and vegetation in “state responsibility areas” (typically non-urban, at fire risk locations) and a minimum of 10 ft clearance around utility poles [4].
- **“enhanced” vegetation management** – practices using technologies and methods that enable shifting from fixed-cycle vegetation management to the use of reliability- and risk-based criteria [5, 6]. These include using LiDAR and satellite imagery to capture vegetation conditions and AI/machine learning analytics to determine which vegetation needs to be prioritized for trimming [7, 8].

These enhanced practices typically involve more aggressive reductions in tree and plant growth.

Strengthens grid reliability and resilience by:

- Preventing initial outages

Improves performance against these hazards:

- Vegetation
- Animal
- Tornado
- Thunderstorm
- Hurricane
- Derecho
- Wildfire
- Ice/Snowstorm



Figure 1. Transmission line tree clearances

Advantages

Because vegetation can impact powerlines due to numerous hazards (branches snapping in ice, blown over in strong winds, and burned close to lines), good vegetation management can reduce outages across a wide range of mild to more extreme events. In an analysis of Duke Energy circuits in North Carolina, researchers found that increasing the frequency of trimming the same section of line by one year (for example going from every 4 years to every 3) would

likely lead to a 13% reduction in vegetation related outages per month.¹ [9]. Additionally, an electric cooperative in the Midwest saw improvements in reliability and decreases in maintenance costs after installing a vegetation management software solution to better track and analyze vegetation impacts on their system. Specifically, they were able to reduce spending by roughly 80% on trimming, while also reducing tree-related outages and duration of those outages by 30% and 45% respectively [10]. Lastly, Bonneville Power Authority in 2008 compared vegetation inspection practices along transmission lines and found that LiDAR inspections were the most accurate in locating clearance violations, although it is roughly 2-3 times more expensive than traditional patrol inspection [11].

When considering the benefits of vegetation management to more extreme events, a Connecticut study found that enhanced tree trimming resulted in a 16-48% reduction in outages during extratropical storms² and thunderstorms [12]. Additionally, vegetation management has also become an increasingly important component of wildfire prevention, both through clearing of flammable brush near power lines and maintaining clearances to prevent equipment-caused ignitions [13].

Disadvantages

Vegetation management is subject to utility rights-of-way, which are not always well-defined and may otherwise be subject to dispute by property owners [14]. Often it is vegetation debris that come from plants outside the utility rights-of-way that cause the most damage in extreme events. For example, post-hurricane analysis in Florida indicated that for vegetation management to be impactful in category 3-5 hurricanes, increasing frequency of trimming would not be helpful without wider rights-of-way [15]. In addition, tree measures may have aesthetic impacts that cause community resistance to them being undertaken [16]. For example, an undergrounding program by the Pepco utility in Washington, D.C. was motivated in part by the goal of reducing conflicts with residents regarding the effects of vegetation management on the District's tree canopy [17].

Costs

Table 1 gives several examples of vegetation management program costs per mile. It should be noted that total costs of such programs also depend on the frequency of the activities. For example, Xcel Energy Minnesota follows a five-year vegetation management cycle. Duke Energy Florida's cycles are three years on feeder systems, five years on laterals, along with annual "patrols" to identify and remove hazardous trees. Florida Power & Light follows a three-year cycle for most feeders, with some – e.g., faster-growing species – on a more frequent mid-cycle schedule, and a six-year cycle on laterals.

¹ Although this analysis excluded major event days (MEDs), they allowed for more "extreme" events to be included than are typically considered because the methodology for defining what is a MED differs from the IEEE standard.

² Occurring when cold air masses interact with warm air masses, over land or water.

Table 1. Examples of utility vegetation management program costs

Utility	Investment Type	Period	Average Cost (per VM cycle, nominal dollars averaged over time periods)
TNNP, Entergy Texas, Oncor, Centerpoint, AEP Texas Central, AEP Texas North, SWEPCO (Texas)	Distribution	1998-2008	\$3k-\$12k/mile [18]
TNNP, Entergy Texas, Oncor, Centerpoint, AEP Texas Central, AEP Texas North, SWEPCO (Texas)	Transmission	1998-2008	\$0.3k-\$9k/mile [18]
Baltimore Gas & Electric, PepCo, Potomac Edison (Maryland)	Distribution, transmission, and substation supply lines	Circa 2013	\$6k/mile [14]
Xcel Energy (Minnesota)	Combined distribution and transmission	2018-2020	\$8.7k/mile [19]
Duke Energy Florida	Distribution	2023-2025	\$11k/mile [20]
Duke Energy Florida	Transmission	2023-2025	\$42k/mile [20]
Florida Power & Light	Distribution	2023-2032	\$4.7/mile [21]
Florida Power & Light	Transmission	2023-2032	\$1.5/mile [21]

References

1. Bohman, A. (2022). "Investing in Power System Resilience: A mixed methods approach to assessing the tradeoffs of resilience strategies." Ph.D. dissertation, Department of Engineering and Public Policy, Carnegie Mellon University. Available at: <https://www.cmu.edu/ceic/research-publications/angelena-bohman-phd-thesis-2022.pdf>
2. Hauer, R., Miller, R. (2021). "Utilities & Vegetation Management in North America: Results from a 2019 Utility Forestry Census of Tree Activities & Operations." Available at: https://www.researchgate.net/publication/350291004_Utility_Vegetation_Management_in_North_America_Results_from_a_2019_Utility_Forestry_Census_of_Tree_Activities_and_Operations
3. <https://www.epa.gov/pesp/integrated-vegetation-management-fact-sheet> United States Environmental Protection Agency. (2008). "Integrated Vegetation Management Fact Sheet." Available at: https://www.epa.gov/sites/default/files/2016-03/documents/ivm_fact_sheet.pdf
4. Rancea, G. V. (2014). "Evaluation of Methods for Control of Vegetation in Utility Corridors." University of San Francisco. Available at: <https://repository.usfca.edu/cgi/viewcontent.cgi?httpsredir=1&article=1008&context=capstone>
5. Huff, B. (2022). "Outsmart Vegetation-Related Power Outages." Available at: <https://www.tdworld.com/vegetation-management/article/21239691/outsmart-vegetationrelated-power-outages>
6. Merten, E. (2023). "How Risk-Based Vegetation Management Slashes Costs." Available at: <https://www.tdworld.com/vegetation-management/article/21258571/how-riskbased-vegetation-management-program-slashes-costs>
7. Wanik, D., Parent, J., Anagnostou, E., Hartman, B. (2017). "Using vegetation management and LiDAR-derived tree height data to improve outage predictions for electric utilities." *Electric Power Systems Research* 146: 236-245. Available at: <https://www.sciencedirect.com/science/article/pii/S0378779617300482>
8. Dubeau, F. (2023). "Using Machine Learning to Improve Vegetation Management In Power Line Corridors." Available at: <https://utilityanalytics.com/2023/02/using-machine-learning-to-improve-vegetation-management-in-power-line-corridors/>
9. Guikema, S. D., Davidson, R. A., & Liu, H. (2006). "Statistical models of the effects of tree trimming on power system outages." *IEEE Transactions on Power Delivery*, 21(3), 1549–1557. <https://doi.org/10.1109/TPWRD.2005.860238>
10. Thompson, T. 2015. "LREC Achieves \$1 Million in Annual Cost Savings" *T&D World*, December. 15. Available at: <https://www.tdworld.com/vegetation-management/article/20966045/lrec-achieves-1-million-in-annual-cost-savings>
11. T&D World. (2010). "Is That Tree too Close?" Available at: <https://www.tdworld.com/home/article/20968846/is-that-tree-too-close>

12. Cerrai, D., Watson, P., Anagnostou, E. (2019). "Assessing the effects of a vegetation management standard on distribution grid outage rates." *Electric Power Systems Research* 175: 105909. Available at: <https://www.sciencedirect.com/science/article/pii/S0378779619302287>
13. Southern California Edison. (2023). "2023-2025 Wildfire Mitigation Plan." Available at: https://www.sce.com/sites/default/files/AEM/Wildfire%20Mitigation%20Plan/2023-2025/2023-03-27_SCE_2023_WMP_R0.pdf
14. Burlingame, M., Walton, P. (2013). "NARUC and MDPSC Cost-Benefit Analysis of Various Electric Reliability Improvement Projects from the End Users' Perspective – Analysis Summary." Available at: <https://pubs.naruc.org/pub/539BA54E-2354-D714-5116-111FF504C6B8>
15. Florida Public Service Commission. (2018). "Review of Florida's Electric Utility Hurricane Preparedness and Restoration Actions." Available at: <https://www.floridapsc.com/pscfiles/website-files/PDF/Publications/Reports/ElectricGas//UtilityHurricanePreparednessRestorationActions2018.pdf>
16. Sierra Club. (2021). "The Harmful Effects of PG&E's Tree Removal Practices and Recommended Alternatives to Prevent Utility Wildfires." Available at: <https://www.sierraclub.org/sites/default/files/sce-authors/u19041/20211202%20PGE%20WHITE%20PAPER%20revised%20final.pdf>
17. Government of the District of Columbia, Executive Office of the Mayor. (2013). "Mayor's Power Line Undergrounding Task Force – Findings & Recommendations." Available at: <https://oca.dc.gov/page/power-line-undergrounding-task-force-findings-and-recommendations>
18. Brown, R. (2009). "Cost-Benefit Analysis of the Deployment of Utility Infrastructure Upgrades and Storm Hardening Programs." Available at: https://ftp.puc.texas.gov/public/puct-info/industry/electric/reports/infra/utlity_infrastructure_upgrades_rpt.pdf
19. Northern States Power Company, d. b. a. Xcel Energy (Minnesota). (2021). "Integrated Distribution Plan 2022-2031." Available at: <https://www.edockets.state.mn.us/EFiling/edockets/searchDocuments.do?method=viewDocument&documentId={2018DC7C-0000-C41B-992F-7ED95D99A9EE}&documentTitle=202111-179347-01&userType=public>
20. Duke Energy Florida. (2022). "2023-2032 Storm Protection Plan." Available at: <https://www.floridapsc.com/pscfiles/library/filings/2022/02368-2022/02368-2022.pdf>
21. Florida Power & Light Company. (2022). "2023-2032 Storm Protection Plan." Available at: <https://www.floridapsc.com/pscfiles/library/filings/2022/02358-2022/02358-2022.pdf>

Vegetation Management

Resilience Investment Guide

SEPTEMBER 2024



BERKELEY LAB

Bringing Science Solutions to the World

www.energy.gov/gdo